PHILIPS Day-Brite CFI

Recessed

FluxGrid LED 1x4

3000, 3800, or 4500 lumens

Project:	
Location:	
Cat.No:	
Туре:	
Lumens:	Qty:
Notes:	

The Philips Day-Brite / Philips CFI Recessed FluxGrid LED offers architectural appeal with "must have" features. Two different lens styles, discrete air handling, integral emergency, and access to the boards and driver from below make FluxGrid an ideal solution for a wide range of applications.

Ordering guide

Example: 2FGG38B840-2-D-UNV-DIM

Width	Family	Ceiling Type	Air Function	Lumens	Color	Length	Center Diffuser	Voltage	Driver	Options
1	FG	G				4				
1 1'	FG FluxGrid	G Grid	Blank [†] Static H Air return	Standard Configurations 30L 3000 nominal delivered lumens 38L 3800 nominal delivered lumens 45L 4500 nominal delivered lumens Base Configurations 41B¹ 4100 nominal delivered lumens	830 80 CRI, 3000K 835' 80 CRI, 3500K 840' 80 CRI, 4000K 850 80 CRI, 5000K	4 4'	D¹ Diffuse (ribbed) DS¹ Diffuse (smooth)	UNV¹ Universal voltage 120-277V 120² 120V 277² 277V 347 347V	DIM¹ O-10V dimming SDIM Step dimming to 40% input power XDIM² MarkX phase dimming L3D³ Lutron Hi-lume A 1% dimming LDE Lutron LDE5 5% dimming DALI DALI	F11 3/8" flex, 3 wire 18 gauge 6' F21 3/8" flex, 4 wire 18 gauge 6' F1/D1 3/8" twin flex, 3 wire 18 gauge 6' for dimmable luminaires F2/5W1 3/8" single flex, 5 wire 18 gauge 6' for dimmable luminaires F2/6W1 3/8" single flex, 6 wire 18 gauge 6' for dimmable and EMLED luminaires GLR1 EMLED1.5 FUSING, fast blow Integral emergency battery pack Integral sensor, daylighting and occupancy, Philips EasySense SNS102 CHIC1 Chicago Plenum rated

Footnotes:

- Base configurations available with noted options.
 XDIM requires 120V or 277V specification.
- 3. Specify 38L or 45L lumen packages only.
- Specify DIM driver option only with DAYOCC controls option. Dimming via wall switch.
 Philips Bodine BSL310, 1100lm nominal delivered.

Accessories (order separately)

- FMA14 1'x4' "F" mounting frame for NEMA "F" mounting
- FGD4L FG 4' ribbed replacement lens
- FGDS4L FG 4' smooth replacement lens

Energy data

Luminaire	Catalog Number	Input Power	Efficacy
	1FGG38L840	31.8	120
	1FGG43L840	36.2	119
1x4 Standard	1FGG48L840	41.5	116
	1FGG54L840	48.9	114
	1FGG74L840	69.2	106
1x4 Base	1FGG42B840	33.9	124





3000, 3800, or 4500 lumens

Application

- 3" deep low profile configuration provides minimal penetration into the plenum space
- Acrylic diffuser available in ribbed and smooth configurations provides even illumination with comfortable appeal
- Standard and base configurations available in multiple lumen packages to suit the needs of various applications
- Lambertian distribution creates uniform horizontal and vertical illuminance on the work plane and reduces scalloping on the walls
- CRI 80 minimum color rendering with balanced spectrum
- LEDs coupled with standard dimming provide prolonged lumen maintenance.
 Optional integral sensors contribute further to LED lumen maintenance
- Designed for use with standard Grid (NEMA "G") or Narrow Grid (NEMA "NFG" ceiling T-bars. Drywall or plaster applications require use with the FMA14 "F" mounting frame accessory (sold and shipped separately)
- Continuous row mounting is possible with a 1" gap between fixtures accommodated by others

Construction/Finish

- Uncomplicated design is 3" deep with minimal material overlap creating several benefits:
 - Less material required
- Less packaging required
- Reduced weight for ease of handling and transit
- Less energy required for construction and assembly
- More luminaires can be shipped per truck to reduce fuel consumption
- Metal side covers are die formed with a conical shape to enhance light distribution and visual aesthetic
- Injection molded lens retainers allow for easy, tool-free access to the LED boards and driver from below, and provide positive lens retention
- Luminaire finish is matte white polyester powder coat for high quality, durable finish
- · T-bar grid clips are integral to the body
- Air return option provides air flow through a unique lens retainer design. Air passes through architectural forms in the lens retainers (each end), and through the end plate of the luminaire. A cover plate is provided to control air flow through the luminaire, or make it static as required
- Integral controls options include sensor mounted in one lens retainer. Controls are commissioned via intuitive Philips app on a Droid smartphone either through NFC or an IR blaster
- EMLED option requires the emergency battery pack be installed with a top side cover. Access from above

Electrical

- Integral sensor options for occupancy sensing and/or daylight harvesting are available for additional energy savings with no reduction of life or increase in installation labor
- Standard configurations provide up to 121 lumens per watt and are available with 5 lumen and 3000, 3500, 4000, and 5000K color temperatures
- Base configurations provide up to 124 lumens per watt and are available in 4100 lumen flux and 3500K and 4000K color temperatures
- LED boards are accessible from below by removal of the lens. Lens removal is tool-free by compressing the sides and pushing to one end
- LED driver is accessible from below by removal of the lens and integral wireway cover. The wireway cover is easily removed with a flat head screwdriver
- Other driver options including step dimming (SDIM, 100%/40%), DALI, phase dimming (XDIM), and Lutron are available
- Five year limited luminaire warranty includes LED boards and driver (emergency driver and batteries have a three year warranty in models so equipped). Visit www.philips. com/warranties for complete warranty information
- TM-21 predicted L70 lumen maintenance up to 85,000 hours
- cETLus listed to UL and CSA standards, suitable for damp locations
- FluxGrid luminaires are DesignLights
 Consortium qualified. Please see the DLC
 QPL list for exact catalog numbers
 (http://www.designlights.org/QPL)

Enclosure

- Opal acrylic diffuser provides visually comfortable lumenance without compromise to luminaire efficacy.
- Diffuser requires no frames or fasteners and can be easily removed from below without the use of tools

General notes


- · All options are factory installed
- · All accessories are field installed
- Many luminaire components, such as reflectors, refractors, lenses, sockets, lampholders, and LEDs are made from various types of plastics which can be adversely affected by airborne contaminants. If sulfur based chemicals, pertroleum based products, cleaning sollutiosn, or other contaminants are expeted in the intented area of use, consult factory for compatibility


DAYOCC

- Integrated fixture mount Philips EasySense sensor featuring daylight and PIR occupancy sensing
- Compatibility with Philips Advance Xitanium SR Sensor Ready LED drivers
- Features automatic or manual on/off scenarios for code compliance and to realize full energy savings potential
- Basic grouping to a wireless switch via an IR interface with the Philips Field App
- Self-powered single rocker switch Illumra #ZBT-S1AWH (sourced by others), up to 40 luminaires may be grouped to a single switch
- Register for the commissioning app at http:// registration.componentcloud.philips.com/ appregistration/
- For more information visit www.philips.com/ EasySense

3000, 3800, or 4500 lumens

Dimensions









Controls sensor integrated into one lens retainer.



The air return option allows air to flow through vents in the lens retainers on each end. Air blades are provided on each end of the luminaire to control air flow to the plenum.





3000, 3800, or 4500 lumens

Photometry

1x4 FluxGrid recessed LED, base configuration, 4100 nominal delivered lumens

LER - 124

Catalog No. 1FGG41B840-4-D-UNV-DIM

 Test No.
 36798

 S/MH
 1.2

 Lamp Type
 LED

 Lumens
 4125

 Input Watts
 34

Comparative yearly lighting energy cost per 1000 lumens – **\$1.94** based on 3000 hrs. and \$.08 pwr KWH.

The photometric results were obtained in the Philips Day-Brite laboratory which is NVLAP accredited by the National Institute of Standards and Technology.

Photometric values based on test performed in compliance with LM-79. $\,$

Candlepower

Angle	End	45	Cross	Back-45
0	1595	1595	1595	1595
5	1569	1584	1590	1584
15	1497	1505	1509	1505
25	1352	1363	1372	1363
35	1150	1177	1196	1177
45	921	980	1005	980
55	684	757	782	757
65	421	523	516	523
75	214	245	233	245
85	41	42	36	42

Degrees Lumens % Luminaire 0-30 1203 28.9 0-40 1939 46.6 0-60 3354 80.6 0-90 4150 99.8 0-180 4160 100

Average Luminance						
Zone	End	45°	Cross			
45	7833	8328	8541			
55	7163	7932	8196			
65	5994	7436	7342			
75	4961	5697	5418			
85	2807	2924	2469			

Coefficients of Utilization

EFFECTIVE FLOOR CAVITY REFLECTANCE 20 PER (pfc=0.20)								
pfc =	20							
Ceil		80			70		5	0
Wall	70	50	30	70	50	30	50	30
RCR								
0	118	118	118	115	115	115	111	111
1	109	105	100	106	102	97	97	94
2	98	91	84	96	89	82	85	81
3	91	80	71	88	79	70	76	68
4	82	70	63	81	69	61	68	60
5	77	64	55	73	63	54	60	53
6	70	57	48	68	56	47	55	46
7	66	52	44	64	51	42	50	41
8	60	47	39	59	46	39	46	38
9	56	44	35	56	42	34	41	34
10	54	40	33	52	40	32	39	32

1x4 FluxGrid recessed LED, standard configuration, 3000 nominal delivered lumens

Catalog No. 1FGG30L840-4-D-UNV-DIM

 Test No.
 36797

 S/MH
 1.2

 Lamp Type
 LED

 Lumens
 2975

 Input Watts
 24

Comparative yearly lighting energy cost per 1000 lumens – \$1.97 based on 3000 hrs. and \$.08 pwr KWH.

The photometric results were obtained in the Philips Day-Brite laboratory which is NVLAP accredited by the National Institute of Standards and Technology.

Photometric values based on test performed in compliance with LM-79.

Candlepower

Angle	Ena	45	Cross	Back-45
0	1156	1156	1156	1156
5	1137	1148	1152	1148
15	1084	1090	1094	1090
25	979	987	994	987
35	833	854	867	854
45	667	711	727	711
55	462	521	548	521
65	305	353	349	353
75	154	177	168	177
85	29	30	26	30

Light Distribution

Degrees	Lumens	% Luminaire
0-30	871	29.3
0-40	1405	47.2
0-60	2411	81
0-90	2970	99.8
0-180	2977	100

Average Luminance

LER - 121

	0		
Zone	End	45°	Cross
45	5667	6042	6184
55	4839	5455	5743
65	4332	5022	4960
75	3579	4111	3906
85	2028	2069	1766

Coefficients of Utilization

EFFEC	TIVE FLO	OR CAVIT	Y REFLE	CTANCE	20 PER (p	fc=0.20)		
pfc =	20							
Ceil		80			70			50
Wall	70	50	30	70	50	30	50	30
RCR								
0	118	118	118	115	115	115	111	111
1	109	105	100	106	102	98	97	94
2	100	92	84	96	90	83	85	81
3	91	81	72	88	79	71	76	69
4	82	71	63	81	69	61	68	60
5	77	64	55	75	63	55	60	54
6	70	57	48	68	56	48	55	47
7	66	53	44	64	52	44	50	42
8	60	47	40	59	46	39	46	39
9	56	44	35	56	44	35	41	34
10	54	40	33	53	40	33	39	32

3000, 3800, or 4500 lumens

Photometry

1x4 FluxGrid recessed LED, standard configuration, 3800 nominal delivered lumens

LER - 121

Catalog No. 1FGG38L840-4-D-UNV-DIM

 Test No.
 36796

 S/MH
 1.2

 Lamp Type
 LED

 Lumens
 3830

 Input Watts
 32

Comparative yearly lighting energy cost per 1000 lumens – **\$2.00** based on 3000 hrs. and \$.08 pwr KWH

The photometric results were obtained in the Philips Day-Brite laboratory which is NVLAP accredited by the National Institute of Standards and Technology.

Photometric values based on test performed in compliance with LM-79. $\,$

Candlepower

End	45	Cross	Back-45
1480	1480	1480	1480
1456	1470	1475	1470
1388	1396	1401	1396
1254	1264	1274	1264
1067	1093	1111	1093
853	911	932	911
633	705	725	705
391	454	447	454
198	227	216	227
38	39	33	39
	1480 1456 1388 1254 1067 853 633 391 198	1480 1480 1456 1470 1388 1396 1254 1264 1067 1093 853 911 633 705 391 454 198 227	1480 1480 1480 1456 1470 1475 1388 1396 1401 1254 1264 1274 1067 1093 1111 853 911 932 633 705 725 391 454 447 198 227 216

Degrees Lumens % Luminaire 0-30 1116 29.1 0-40 1798 46.9 0-60 3111 81.2 0-90 3831 100 0-180 3832 100

Average Luminance						
Zone	End	45°	Cross			
45	7255	7742	7919			
55	6636	7383	7595			
65	5554	6453	6355			
75	4592	5281	5019			
85	2586	2683	2297			

Coefficients of Utilization

EFFEC	TIVE FLO	OR CAVIT	Y REFLE	CTANCE 2	0 PER (p	fc=0.20)		
pfc =	20							
Ceil		80		70			50	
Wall	70	50	30	70	50	30	50	30
RCR								
0	118	118	118	115	115	115	111	111
1	109	105	100	106	102	98	97	94
2	100	92	84	96	90	83	85	81
3	91	81	72	88	79	71	76	69
4	82	71	63	81	69	61	68	60
5	77	64	55	75	63	55	60	53
6	70	57	48	68	56	47	55	47
7	66	52	44	64	52	42	50	42
8	60	47	39	59	46	39	46	39
9	56	44	35	56	42	35	41	34
10	54	40	33	52	40	33	39	32

1x4 FluxGrid recessed LED, standard configuration, 4500 nominal delivered lumens

Catalog No. 1FGG45L840-4-D-UNV-DIM

 Test No.
 36795

 S/MH
 1.2

 Lamp Type
 LED

 Lumens
 4546

 Input Watts
 39

Comparative yearly lighting energy cost per 1000 lumens – \$2.03 based on 3000 hrs. and \$.08 pwr KWH.

The photometric results were obtained in the Philips Day-Brite laboratory which is NVLAP accredited by the National Institute of Standards and Technology.

Photometric values based on test performed in compliance with LM-79.

Candlepower

Angle	End	45	Cross	Back-45
0	1751	1751	1751	1751
5	1723	1739	1746	1739
15	1643	1652	1658	1652
25	1484	1495	1507	1495
35	1263	1293	1314	1293
45	1010	1077	1103	1077
55	750	833	859	833
65	462	558	551	558
75	235	269	257	269
85	45	46	40	46

Light Distribution

_		
Degrees	Lumens	% Luminaire
0-30	1320	29
0-40	2129	46.8
0-60	3683	81
0-90	4548	100
0-180	4548	100

Average Luminance

Zone	End	45°	Cross
45	8587	9155	9376
55	7860	8728	9001
65	6577	7931	7834
75	5446	6254	5957
85	3069	3193	2773

LER - 118

Coefficients of Utilization

EFFEC	TIVE FLO	OR CAVIT	TY REFLE	CTANCE 2	20 PER (p	fc=0.20)			
pfc =	20								
Ceil	80			70				50	
Wall	70	50	30	70	50	30	50	30	
RCR									
0	118	118	118	115	115	115	111	111	
1	109	105	100	106	102	98	97	94	
2	98	91	84	96	90	82	85	81	
3	91	81	72	88	79	71	76	69	
4	82	70	63	81	69	61	68	60	
5	77	64	55	75	63	55	60	53	
6	70	57	48	68	56	47	55	46	
7	66	52	44	64	52	42	50	42	
8	60	47	39	59	46	39	46	39	
9	56	44	35	56	42	35	41	34	
10	54	40	33	52	40	33	39	32	

© 2016 Koninklijke Philips N.V. All rights reserved. Philips reserves the right to make changes in specifications and/or to discontinue any product at any time without notice or obligation and will not be liable for any consequences resulting from the use of this publication. philips.com/luminaires



Philips Lighting North America Corporation 200 Franklin Square Drive, Somerset, NJ 08873 Tel. 855-486-2216

Philips Lighting Canada Ltd. 281 Hillmount Rd, Markham, ON, Canada L6C 2S3 Tel. 800-668-9008