

## Brackets, Clamps, Partitions

			
<b>CI820-DX</b>	<b>CI820D</b>	<b>CILRW</b>	<b>CILA CLAMP</b>
			
<b>CISSX-6</b>	<b>CI1004-P</b>	<b>CI1104-P</b>	<b>CI2104-P</b>



Cat. No.	Description
<b>Rework Support Brackets</b>	
<b>CI820D</b>	Device box supports. Max. wall thickness 1 in.
<b>CI820-DX</b>	Device box support
<b>CILRW</b>	For installing CI-1104 series of boxes with ears, in closed wall "rework" applications. Complete with an 8-32 x 1-1/2 screw
<b>Universal Cable Clamps (for BX / Loomex)</b>	
<b>CILA CLAMP</b>	Supplied with screws
<b>Support Brackets</b>	
<b>CISSX-6</b>	Support bracket extension for 6 in. metal stud
<b>Device Box Partitions</b>	
<b>CI1004-P</b>	Steel partitions for 2 in., 2-1/2 in. and 3 in. deep outlet boxes
<b>CI1104-P*</b>	Steel partitions for 2-1/2 in. deep gangable boxes. To be used with CI-1104 / CI-3104 Series of boxes
<b>CI2104-P</b>	Steel partitions for 2 in. and 2-1/2 in. deep outlet boxes

\*Note: Install partition while ganging boxes

In accordance with C.E.C. 2012 Edition, Rule 12-3030: Conductors that are connected to different power or distribution transformers or other different sources of voltage shall not be installed in the same box, cabinet, or fitting unless a barrier of sheet steel not less than 1.3 mm thick or a flame-retardant nonmetallic insulating material not less than 1.6 mm in thickness is used to divide the space into separate compartments for the conductors of each system.