

M120/35.FF

ABB contact for Canada [Print to Pdf..](#)

General Information

Extended Product Type:	M120/35.FF
Product ID:	1SNA115146R1500
EAN:	3472591151466
Catalog Description:	M120/35.FF
Long Description:	M120/35.FF Power Terminal Blocks - Feed-through - Grey, 70mm ² RatedCrossSection, 35mm Spacing G32, TH 35-7.5, TH 35-15 Rail



Categories

Products » Low Voltage Products and Systems » Connection Devices »
Terminal Blocks » Power Terminal Blocks

Ordering

EAN:	3472591151466
Minimum Order Quantity:	10 piece
Customs Tariff Number:	85369010

Dimensions

Product Net Width:	35.0 mm
Product Net Height:	69.0 mm
Product Net Depth:	51.0 mm
Product Net Weight:	130.00 g

Container Information

Package Level 1 Units:	10 piece
Package Level 1 Width:	135 mm
Package Level 1 Height:	74 mm
Package Level 1 Length:	175 mm
Package Level 1 Gross Weight:	1.30000 kg
Package Level 1 EAN:	3472591151466
Package Level 2 Units:	160 piece
Package Level 2 Width:	300 mm
Package Level 2 Height:	300 mm
Package Level 2 Length:	500 mm
Package Level 2 Gross Weight:	21.3 kg
Package Level 3 Units:	3840 piece
Product Packing Type:	Box

Environmental

RoHS Status:	Following EU Directive 2002/95/EC August 18, 2005 and amendment
---------------------	---

Technical UL/CSA

Maximum Operating Voltage Main Circuit 600 V
UL/CSA:

Additional Information

Color: Grey
Connecting Capacity-Main Circuit: Stud / Flexible 1x 2.5-70 mm²
 Stud / Rigid 1x 2.5-70 mm²
Connection Type: Stud
Function: Feed-through
IIT Publishing Status: Level 0 - Information enabled
Mounting on DIN Rail: G32 (32 x 15 mm Mounting Rail) acc. to IEC 60715
 TH35-7.5 (35 x 7.5 mm Mounting Rail) acc. to IEC 60715
 TH35-15 (35 x 15 mm Mounting Rail) acc. to IEC 60715
Product Main Type: M120/35.FF
Product Name: Terminal block
Rated Cross-Section: 70 mm²
Rated Current (I_n): Main Circuit 192 A
Rated Short-time Withstand Current (I_{cw}): for 1.0s 8000 A
Rated Voltage (U_r): 1000 V
Spacing: 35 mm

Certificates and Declarations (Document Number)

CSA Certificate: TBD-from cat 2010
cUL Certificate: 1SND165000A0203
Declaration of Conformity - CE: 1SND225008C1006
GOST Certificate: 1SND161005A1104
RoHS Information: 1SND230022F0202

Classifications

ETIM 4.0: EC000897 - Feed-through terminal block
ETIM 5.0: EC000897 - Feed-through terminal block
Object Classification Code: X
