## LIGHTOLIER

by (signify

## Downlighting

CorePro LED 4"

CP4 Downlight



Project:		
Location:		
Cat.No:		
Туре:		
Lamps:	Qty:	
Notos:		

example: CP4RB07830W



## Ordering guide

Core value LED downlight for new construction and remodel applications that installs in many existing residential and commercial applications.

Catalog Number	Aperture	CRI	сст	Lumens	System Watts (Max)	Efficacy (lm/W)	Voltage
CP4RB07830W	4-inch	80	3000K	800 lm	11	73	120
CP4RB07930W	4-inch	90	3000K	7501m	11	68	120

## Features

- 1. **Reflector/Flange**: One piece self flange cast aluminum, powder coated, non yellowing, white baffle and flange.
- 2. Lens: High transmittance lens allowing for smooth, diffused light pattern.
- 3. **Power supply:** Class 2 driver. Factory wired electronic LED driver (see Electrical section for specifications).
- 4. LED board: Light emitted source.
- 5. Friction spring: Stainless steel.
- 6. Power connection: Trim features quick connect plug installed as standard installation into CP4RN housing with mating connector. Trim ships with a medium base socket adapter whip for installation into 4" incandescent housings with medium base sockets.
- 8. Lifetime: Expected lifetime 50,000 hours and backed by a 5-year warranty (see Philips.com/ warranties for details).

## **Electrical**

**Electronic power supply:** RoHS compliant\* Class 2 power unit for use in a dry and damp locations. Complies with FCC.

**Dimming:** All luminaires are intended for use with TRIAC type dimmers. Go to http://www.lightolier. com/MKACatpdfs/LED-DIM.PDF for the latest dimming switch capability information. 10%-100% dimming range.

Lumen Output	Input Voltage	Input Frequency		Max. Input Current Power			Min. Temp. Operating
800lm	120 V	50/60Hz	0.09A	11W	< 30%	> .9	-20° C

Performance data based on 80 CRI 3000K.

\* Restrictions on Hazardous Substances (RoHS) is a European directive (2002/95/EC) designed to limit the content of 6 substances [lead, mercury, cadmium, hexavalent chromium, polybrominated biphenyls (PBB), and polybrominated diphenyl ethers (PBDE)] in electrical and electronic products. For products used in North America compliance to RoHS is voluntary and self-certified.

## Labels

cULus listed for wet locations. Energy Star certified.

Title 24 Certified to meet high efficiency requirements; 90 CRI configuration only.




## **CP4** CorePro LED 4" Downlight


## CP4RN: 4" IC/Airseal frame-in kit housing

**Housing** - Constructed of formed aluminum. For use in direct contact with thermal insulation. Adjusts vertically in plaster frame to accommodate ceilings 1/2" to 1-1/2" thick. Ceiling opening 4 1/2".

Electrical Connection - LED quick-connect adapter


- Junction Box- galvanized steel with two snap-on covers and grounding pigtail. Knockouts for 1/2" & 3/4" conduit and Romex knockouts with strain relief
- **Bar Hangers:** Pre-installed pre-nailed style bar hangers telescope from 16" to 24". Vertical design of interlocking bar hangers prevents sagging even at full 24" extension. Style bar hangers may be used on either long or short axis of housing.
- IC frame-in Kit Housing is cULus Listed for direct contact with thermal insulation cULus Listed for Damp Locations and Through Branch Wiring, 4 in/4 out.
- AirSeal<sup>™</sup>: Fixture is AirSeal<sup>™</sup> rated according to ASTM E283 to no more than 2.0 cubic feet of air per minute at 75 pascals. Fixture meets Washington State Energy Code and Energy Conservation Code.





## **CP4** CorePro LED 4" Downlight


## **Dimensions**



## E26 Compatibility\*

Manufacturer	Model
Philips	CP4RN, FDIC4V50, P4, P4R, P4ASIC, P4GU, P4RGU, R4, RR4, RR4, R4ASICG,
Halo	H991CAT, H99T, H99RT,
Seagull	1179, 1105
All-Pro	E1400ATSB

\* Any other luminaires meeting theses dimensions as shown are also compatible.






4"unit shown with standard (E26) adapter to fit medium base sockets

**CP4RN**: IC c/w LED Connector New Construction Housing



## **CP4** CorePro LED 4" Downlight

## CP4RB07830W



#### 343 0 5 342 32 10 338 15 329 91 20 316 25 301 134 30 282 35 261 157 40 239 45 50 214 155 186 55 127 156 60 125 65 93 79 70 63 75 80 34 27 13 5 85 4 0 90

Efficacy:

CCT<sup>3</sup>:

CRI

75.4lm/w

68.8 lm/w

3000 K

>90

3000 K

>80

Angle Mean CP Lumens

### Single unit data

Height to Lighted Plane	Initial center beam foot-candles	Beam dia. (ft)*
5'	14	6.0
6'	10	7.2
7'	7	8.4
8'	5	9.6
9'	4	10.8
* Beam diame	ter is where foot-ca	ndles

\* Beam diameter is where foot-candles drop to 50% of maximum.

## Multiple unit data - RCR 2

Spacing on center	Initial center beam foot-candles	Watts per sq.ft.
33.6	0.47	0.55
22.1	0.31	0.36
15.8	0.22	0.26
13.1	0.19	0.21
10.5	0.15	0 17

38'x38'x10' Room, Workplane 2.5' above floor, 80/50/20% Reflectances

### **Coefficients of utilization**

Ceiling		80%			70	)%	50	0%	30	0%	0%	
Wal	ll	70	50	30	10	50	10	50	10	50	10	0
RCF	2	Zona	al cav	ity m	etho	d - Ef	fectiv	/e flo	or ref	lecta	nce =	20%
	0	119	119	119	119	116	116	111	111	106	106	100
~	1	110	106	102	99	104	97	100	94	96	91	87
Room Cavity Ratio	2	101	94	88	82	92	81	88	80	85	78	74
Ra	3	93	83	76	70	82	69	79	68	76	67	63
ťζ	4	85	74	66	60	73	59	70	58	68	58	55
avi	5	79	67	58	52	65	52	63	51	61	50	48
õ	6	73	60	52	46	59	45	57	45	56	45	42
ъ	7	68	55	46	40	54	40	52	40	51	40	38
Ã	8	63	50	42	36	49	36	48	36	47	36	34
	9	59	46	38	33	45	33	44	33	43	32	30
	10	55	43	35	30	42	30	41	30	40	29	28

### Zonal lumens & percentages Adjustment factors

Zone	Lumens	%Luminaire	Color temperature (CCT)
0-30	258	31.9%	4000K = 105%
0-40	414	51.3%	
0-60	696	86.3%	
0-90	807	100.0%	

## CP4RB07930W

Report<sup>1</sup>: BTS165311

Spacing Criterion:

Output lumens:

Output lumens: Input Watts<sup>2</sup>:

Spacing Criterion:

Input Watts<sup>2</sup>:

Candela Curves	Angle	Mean CP	Lumens
	0	377	
	5	370	35
	10	358	
100	15	340	98
	20	317	
	25	289	140
	30	259	
	35	228	154
200	40	195	
	45	160	139
	50	125	
	55	92	100
300	60	64	
	65	40	54
	70	22	
400	75	10	18
400	80	4	
	85	1	3
	90	0	
Report <sup>1</sup> : BTS165312			

742.7 lms Efficacy:

CCT<sup>3</sup>:

CRI:

10.8 W

1.1

806.9lms

10.7W

1.2

## Single unit data

Height to Lighted Plane	Initial center beam foot-candles	Beam dia. (ft)*
5'	15	5.5
6'	10	6.6
7'	8	7.7
8'	6	8.8
9'	5	9.9
* Beam diame	ter is where foot-ca	ndles

\* Beam diameter is where foot-candles drop to 50% of maximum.

## Multiple unit data - RCR 2

Spacing on center	Initial center beam foot-candles	Watts per sq.ft.						
5'	33.6	0.47						
6'	22.1	0.31						
7'	15.8	0.22						
8'	13.1	0.19						
9'	10.5	0.15						
38'x38'x10' Room, Workplane 2.5' above floor, 80/50/20% Reflectances								

## **Coefficients of utilization**

		-										
Ceiling		80%			70	70%		50%		30%		
Wal	ll	70	50	30	10	50	10	50	10	50	10	0
RCF	2	Zona	al cav	ity m	etho	d - Ef	fectiv	/e floo	or ref	lecta	nce =	20%
	0	119	119	119	119	116	116	111	111	106	106	100
~	1	111	107	103	100	105	99	100	96	97	93	88
Ratio	2	102	95	90	85	94	84	90	82	87	80	76
Ra	3	94	85	78	73	84	72	81	71	78	70	66
Room Cavity	4	87	77	69	63	75	63	73	62	71	61	58
aci	5	81	69	61	55	68	55	66	55	64	54	52
Ŭ	6	75	63	55	49	62	49	60	49	59	48	46
ωŭ	7	70	58	50	44	57	44	55	44	54	43	41
ê	8	65	53	45	40	52	40	51	39	50	39	37
_	9	61	49	41	36	48	36	47	36	46	36	34
	10	58	45	38	33	45	33	44	33	43	33	31

### Zonal lumens & percentages

Zone	Lumens	%Luminaire
0-30	274	36.9%
0-40	428	57.6%
0-60	667	89.8%
0-90	743	100.0%

1. Correlated Color Temperature within specs as defined in ANSI\_NEMA\_ANSLG C78.377-2008: Specifications for the Chromaticity of Solid State Lighting Products. 2.Wattage: controlled to within 5%

3. Tested using absolute photometry as specified in LM79: IESNA Approved Method for the Electrical and Photometric Measurements of Solid-State Lighting Products.

# Signify

© 2019 Signify Holding. All rights reserved. This document may be subject to change. No representation or warranty as to the accuracy or completeness of the information included herein is given and any liability for any action in reliance thereon is disclaimed. All trademarks are owned by Signify Holding or their respective owners.

200 Franklin Square Drive, Somerset, NJ 08873 Telephone 855-486-2216 Signify Canada Ltd. 281 Hillmount Road, Markham, ON, Canada L6C 2S3 Telephone 800-668-9008